

Dated: 16-06-2023

No.20/FSR/DFO/UDP/2023

To,  
The Principal,  
S.M.S English Medium School,  
Brahmavar - 576 213  
Brahmavara Taluk,  
Udupi District.

Sir,

Sub: Issue **Renewal of 'Fire safety Compliance Certificate'** with respect to fire prevention, fighting and evacuation measures maintained to S.M.S English Medium School building at Sy No. 201/1B3, 201/2B3, 202/1B3 of Varamballi Village, Brahmavara Taluk, Udupi District.

- Ref: 1) \* FSR Certificate No. 36/FSR/RFO/MR/2019, dated 04/07/2019.  
2) Compliance Certificate No. 36/FSR/RFO/MR/2022(UD) dated 24/03/2022  
3) Your letter dated 06-03-2023  
4) Report No. 41/Renewal-CC/FSO/UDP/2023, Dated: 14/06/2023  
Of the Fire Station Officer, Fire Station Udupi.


<<<<<>>>>>

With reference to subject above cited, 'Fire Safety Recommendation' was issued wide reference (1) to the premises of S.M.S English Medium School building at Sy No. 201/1B3, 201/2B3, 202/1B3 of Varamballi Village, Brahmavara Taluk, Udupi District, with a condition to fulfill the recommendations and compliance the same. The Compliance certificate was issued to the building vide ref. (2).

With reference cited (3) above, the Principal of S.M.S English Medium School had requested for the renewal of compliance certificate from our department, the fire Station Officer, Udupi was re- inspected on 25-03-2023 & 12-06-2023 and submitted his report vide reference(4).

Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the renewal of 'Fire Safety Compliance Certificate' to S.M.S English Medium School building subject to proper maintenance of fire fighting installations in good working conditions and to arrange the training of 40% of employees within 3 months and to renew the fire safety Recommendation report for every year.

Yours faithfully,



District Fire Officer  
Karnataka State Fire & Emergency Services  
Udupi District, Udupi  
16/06/23

Copy to:

- ✓ 1. The Deputy Director, DDPI office, Udupi Taluk, Udupi District.
2. The Deputy Director (FP), KSFES, Bengaluru.
3. Fire Station Officer, Udupi.

ATTESTED

Principal

S.M.S. ENGLISH MEDIUM SCHOOL  
BRAHMAVAR - 576 213



## TEST & WARRANTY CERTIFICATE

Cert. No. Apr/2023/CERT/1423

Date: 01-04-2023

To,  
M/s SMS English Medium  
School- Brahmavar

This is to certify that the below mentioned Fire Extinguishers have been refilled & hydraulically

Pressure tested by us as per the IS specification and the same is Warranted for one year from the date of Refill

- Next Refilling Due On April/2024

Sl.No.	Description	Qty	Result
1.	ABC type Fire Extinguisher 6Kg capacity	04Nos	Satisfactory
2	Co2 type Fire Extinguisher 4.5Kg capacity	01Nos	Satisfactory
3	ABC type Fire Extinguisher 5Kg capacity	03Nos	Satisfactory
4	ABC type Fire Extinguisher 4Kg capacity	07Nos	Satisfactory
5	ABC type Fire Extinguisher 2Kg capacity	51Nos	Satisfactory

For  
Manipal Services

Authorized Signatory /

**ATTESTED**

**For MANIPAL SERVICES**

*Principal*  
S.M.S. ENGLISH MEDIUM SCHOOL  
BRAHMAVAR - 576 213

*Proprietor*

